

**Blackpool Council Licensing Service**  
Representation made by a Responsible Authority

**Responsible Authority**

Name of Responsible Authority	<b>Health and Safety</b>			
Name of Officer <i>(please print)</i>	Gareth Shaw			
Signature of Officer	<b>G Shaw</b>			
Contact telephone number	<b>478315</b>			
Date representation made	<b>02</b>	<b>07</b>	<b>2015</b>	
Do you consider mediation to be appropriate				No


**Premises Details**

Premises Name	<b>Bells Convenience Store</b>			
Address	151 Palatine Road			
	Blackpool			
	Lancashire			
Post Code	FY1 4DN			

**Details of your representation (Please refer and attach any supporting documentation)**

A visit to this premise on the 15<sup>th</sup> of June revealed the following issues;

- 1) A smashed socket in the shop area next to drinks live at >200Volts and a cable routed across a traffic route without any physical protection.



2) Cabling that requires further investigation.



3) In addition to the above the premise was in a very poor state of cleanliness.

The electrical socket was made safe by isolating at the consumer unit and a prohibition notice served to prevent use until made safe.

In addition to the prohibition notice improvement notices were served for an electrical condition report, PAT testing and cleaning of the premise.

Blackpool Council REF: PNI/15/06 /2015

HEALTH AND SAFETY AT WORK ETC ACT 1974  
(Sections 22, 23 and 24)

**PROHIBITION NOTICE**

To: Mr Aman Khan  
Trading as Belle Curviness Store  
1 Cornett Street

Public Protection Officer for the Health and Safety  
Enforcement, Progress House, Clifton Road, Blackpool,  
FY4 4US Tel. no. (01253) 478315 hereby give you notice  
that I am of the opinion that the following activities, namely:

Use of the electrical  
circuit board in the  
socket.

which are being carried on by you/likely to be carried on by  
you/under your control\*  
at 151 Palatine Road  
Blackpool  
FY14DN.

involve, or will involve, a risk of serious personal injury and  
that the matters which give rise/will give rise\* to the said  
risks are:

Live electrical connecting  
at a broken socket.

I am further of the opinion that the said matters involve/will  
involve\* contraventions of the following statutory provisions:-  
The Health and Safety  
Work etc Act 1974 S2+3.  
because  
The electrical system is  
damaged.

and I hereby direct that the said activities shall not be carried  
on by you or under your control immediately.

Signature *Aman Khan* Date 15/6/15

Being an inspector appointed by an instrument in writing  
made pursuant to Section 19 of the said Act and entitled to  
issue this notice.

A Prohibition Notice is also being served on

of

related to the matters contained in this notice. This is a  
relevant notice for the purpose of the Environment and  
Safety Information Act 1988. YES/NO\*

A further visit was carried out to check compliance with the prohibition notice on the 1<sup>st</sup> of July 2015 and it was found to have been temporarily repaired with Sellotape and Gaffa tape and put back into action. There was still a large hole to the underneath of the socket exposing live electrical connections at >200Volts

The socket was again made safety by isolating at the consumer unit and this will now be reported for consideration of prosecution.



Mr Jeyabalan who was present during both visited stated as I was leaving that he was going to close the business as it was not making any money and that Blackpool council were too strict.