



KEY		
	FIRE EXTINGUISHER: E. G. 13A OR 34B. NUMBER INDICATES THE EXTINGUISHING CAPABILITY AND THE LETTER INDICATES THE CLASS OF FIRE THAT THE EXTINGUISHER IS SUITABLE FOR. FOR FURTHER INFORMATION SEE OUR GUIDANCE NOTE FSGN 8.	
	AQUEOUS FILM FORMING FOAM EXTINGUISHER.	
	CLASS F TYPE EXTINGUISHER.	
	FIRE BLANKET EXTINGUISHER.	
	CARBON DIOXIDE FIRE EXTINGUISHER.	
	DRY POWDER EXTINGUISHER.	
	FOAM FIRE EXTINGUISHER.	
	CCTV	
	MAINTAINED EMERGENCY LIGHT FITTING	
	AREA FOR LICENSABLE ACTIVITIES	
	HEAT DETECTOR	
	HEAT DETECTOR & SOUNDER	
	VOID DETECTOR	
	PANEL	
	SMOKE DETECTOR	
	SMOKE DETECTOR & SOUNDER	
	SMOKE DETECTOR & SOUNDER & BEACON	
	BREAK GLASS	
	FIRE PANEL	
	CALL POINT	
	LAST MAN OUT SWITCH AFFL. 1800MM	
	FIREMANS SWITCH	
NOTES:		
SYSTEM DESIGNED TO BS 5839 PART 1: 2002		
CATEGORY OF SYSTEM: L2		
SYSTEM DETAILS: CONVENTIONAL FIRE PANEL		
INSTALLATION METHOD: FP200G INSTALLED ON CABLE TRAY FIXED TO STRUCTURE		
ALL FIRE FIGHTING EQUIPMENT SHOULD BE SO PLACED AS TO BE READILY AVAILABLE FOR USE. THEY SHOULD BE MOUNTED ON BRACKETS OR SUITABLE SHELVES IN CONSPICUOUS POSITIONS SO THAT THE CARRYING HANDLES OF THE LARGER HEAVIER EXTINGUISHERS ARE APPROXIMATELY 1.5M FROM THE FLOOR, AND THE HANDLES OF THE SMALLER FIRE EXTINGUISHERS/BASES OF FIRE BLANKETS ARE APPROXIMATELY 1.1M FROM THE FLOOR.		
ALL WALLS AND PARTITIONS TO BE MINIMUM HALF HOUR FIRE RESISTANT		
EMERGENCY LIGHTING TO COMPLY WITH BS 5266 PART 1		
FIRE SAFETY RELATED SIGNS AND NOTICES TO COMPLY WITH BS 5499		
FIRE FIGHTING EQUIPMENT TO COMPLY WITH BS 5306		
WALL AND CEILING LININGS ARE TO BE CLASS 1 SPREAD OF FLAME (AS DEFINED BY BS 476 PART 7) IN PUBLIC AREAS AND CLASS 0 IN ESCAPE ROUTES.		
UPHOLSTERED SEATING FURNITURE TO COMPLY WITH THE FOLLOWING: -IGNITION SOURCE (CIGARETTE TEST) AS SPECIFIED IN BS 5852 PART 2 FIRE TEST FOR FURNITURE METHODS FOR TEST IGNITABILITY BY SMOKERS. -BS 5852 PART 2 FIRE TEST FOR FURNITURE METHODS OF TEST FOR THE IGNITABILITY OF UPHOLSTERED COMPOSITES FOR TESTING BY FLAME SOURCE. MINIMUM TEST TO BE CRIB IGNITION SOURCE 5.		
FABRICS THAT HAVE HAD A FLAME RETARDANT TREATMENT TO PASS THE WATER SOAK TEST AS DETAILED IN BS 5851. TEST CERTIFICATES TO BE SUBMITTED TO THE FIRE AUTHORITY.		
CURTAINS AND DRAPES TO SATISFY TYPE B PERFORMANCE REQUIREMENTS TO BE BS 5867 PART 2.		
ARTIFICIAL FOLIAGE AND DECORATIVE EFFECTS TO BE FIRE RETARDANT TO THE SATISFACTION OF THE AUTHORITY.		
COVER COUNT		
TOTAL INTERNAL: 224		
TOTAL EXTERNAL : 69		
REVISIONS:		
CODE:	DATE:	DESCRIPTION:
B3 DESIGN JERS PROJECT NO: 986 CLIENT/PROJECT: LAS IGUANAS BLACKPOOL SITE ADDRESS: 66-74 PROMENADE 2-4 CHURCH ST. BLACKPOOL FY1 1HH DATE: 04/06/2015 DRAWN: OP CHECKED: MB SCALE: 1:50 @ A1 TITLE: LICENSING PLAN FOR INFORMATION DWG. NO: 986-109 REV: -		