

Blackpool Council Licensing Service

Representation made by a Responsible Authority  
In support of an application for the Review of an existing  
Premises Licence or Club Premises Certificate

**Responsible Authority making representation**

Name of Responsible Authority	<b>Health and Safety Enforcement</b>			
Name of Officer <i>(please print)</i>	Gareth Shaw			
Contact telephone number	478315			
Date representation made	<b>17</b>	<b>06</b>	<b>2014</b>	
Do you consider mediation appropriate				YES

**Name of Responsible Authority / Applicant who requested a review of this Licence**

Licensing Authority

**Premises Details**

Premises Name	<b>Locals</b>
Address	113-115 Lytham Road
	Blackpool
Post Code	FY1 6DS

**Details of your representation in support of the review application**

(Please reference & attach supporting any documentation)

This authority wish to support this review by detailing health and safety issues noted during a visit carried out on the 21<sup>st</sup> may 2014:


- 1) General litter around entrance to shop.



2) Removed false ceiling exposing unsupported cabling.



3) Unsupported cables and obstructed fire extinguisher.



4) Staircase with no handrail, uneven and loose steps in parts.



5) Unsupported cables and wiring that requires further investigation.



6) Scorched and cracked socket still live and associated plug top.



7) Temporary wiring to shop connected without physical protection



8) Unrated temporary connection in use with no physical protection exposing conductors at >200Volts.



9) Tales to electric meter tampered with and security stickers damaged.



10) Meter earth bar cover missing.



11) Wiring that requires further investigation.



12) Dripping meter compound suggesting overloading of electric supply.



13) Exposed Live electrical conductors and light fitting a head height



14) A prohibition notice was served on the electrical installation until proven as safe.



